

Fire Alarm Systems

Requirements:



- Fire alarm systems shall meet NFPA 72 current edition adopted by the State of NH.
- Stamped plans shall be submitted prior to work starting.
- Plans will be reviewed and contact made within 2 weeks.
- Knox box will be located near closest entry to alarm panel (form available at the Bow Fire Department)
- Exterior strobes Red for alarm Green for suppression will be placed in visible location.
- Changes to accepted plans shall be resubmitted for review.
- Plans may be subject to third party review.
- Inspections need to be scheduled at least 2 weeks in advance of date inspection is requested.
- Smoke detectors shall be tested with can smoke (not a magnet).
- Heat detectors shall be tested with heat source (not a magnet).
- All devices and panels shall be CAT 30 key.