

Oil Burners



General Requirements:

- Permit shall be obtained prior to installation unless in an emergency situation.
- Installation shall be done in accordance to NFPA 31 Most recent edition adopted by the State of NH.
- Oil line shall be sleeved and secured from damage.
- Installer is responsible for requesting inspection for the home owner.

Special Town of Bow Requirements:

- Tank shall have a capped pipe to the joist above to prevent tank from rising if basement floods.
- Fire rated 5/8 sheetrock is required over the burner at least 4 square feet with burner centered.