

## Sprinkler Systems



### Requirements:

- Sprinkler Systems shall meet NFPA 13,13D or 13R current edition adopted by the State of NH.
- Stamped plans shall be submitted prior to work starting.
- Plans will be reviewed and contact made within 2 weeks.
- Changes to accepted plans shall be resubmitted for review.
- Plans may be subject to third party review.
- Inspections need to be scheduled at least 2 weeks in advance of date inspection is requested.