



TOWN OF BOW

Fire Department

7 Knox Road, Bow NH 03304

Office (603) 223-3960 | Fax (603) 223-3961 | Website www.bownh.gov

Commercial Fire and Life Safety Submittals and Inspections

Building Permit No. _____ Contractor: _____ Phone: _____

Property Owner: _____ Phone: _____

Property Address: _____ Map/BL/Lot: _____

The Bow Fire Department is required by law to follow the State Fire Code as defined by NH RSA Chapter 153 and Administrative Rules Saf-C6000. The most current list of adopted Building and Fire Codes are attached. When conflicts between the IBC and Life Safety Code exist, the more stringent requirement will be enforced.

(Below to be completed by Fire Department)

Life Safety					
	Date	Fee	Fee Rc'd	Status	Inspector
Plans Review					
Inspection					
Re-Inspection (if needed)					
Fire Alarm System: Required Not Required Date: _____					
	Date	Fee	Fee Rc'd	Status	Inspector
Plans Review					
Inspection/Acceptance					
Re-Inspection (if needed)					
Automatic Suppression System: NFPA 13 NFPA 13R Not Required Date: _____					
	Date	Fee	Fee Rc'd	Status	Inspector
Plans Review					
Rough Inspection					
Final Inspection/Acceptance					
Re-Inspection (if needed)					
Specialty System: NFPA 13 NFPA 13R Not Required Date: _____					
	Date	Fee	Fee Rc'd	Status	Inspector
Plans Review					
Rough Inspection					
Final Inspection/Acceptance					
Re-Inspection (if needed)					



State of New Hampshire

DEPARTMENT OF SAFETY
Division of Fire Safety
Office of the State Fire Marshal

nh.gov/firemarshal



Robert L. Quinn
Commissioner

Sean P. Toomey
State Fire Marshal

State of New Hampshire List of Adopted Building and Fire Codes

All Occupancies:

- 2021 NFPA 1, Fire Code as amended by Saf-FMO 300
- 2021 NFPA 101, Life Safety Code as amended by Saf-FMO 300
- 2019 NFPA 13, Standard for the Installation of Sprinkler Systems
- 2019 NFPA 13R, Standard for the Installation of Sprinkler Systems for Low-Rise Residential Occupancies
- 2020 NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems
- 2021 NFPA 30, Flammable and Combustible Liquids Code
- 2021 NFPA 30A, Code for Motor Fuel Dispensing Facilities and Repair Garages as amended by Saf-FMO 300
- 2020 NFPA 31, Standard for Installation of Oil-Burning Equipment as amended by Saf-FMO 300
- 2021 NFPA 54, National Fuel Gas Code as amended by Saf-FMO 300
- 2020 NFPA 58, Liquefied Petroleum Gas Code as amended by Saf-FMO 300
- 2020 NFPA 70, National Electrical Code (NEC) with NH Amendments
- 2019 NFPA 72, National Fire Alarm and Signaling Code
- 2021 NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations
- 2019 NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances
- 2019 NFPA 914, Code for Fire Protection of Historic Structures
- 2021 International Building Code (IBC) with NH Amendments
- 2021 International Residential Building Code (IRC) with NH Amendments
- 2018 International Energy Conservation Code (IEC) with NH Amendments
- 2021 International Existing Building Codes (IEBC) with NH Amendments
- 2021 International Mechanical Code (IMC) with NH Amendments
- 2021 International Plumbing Code (IPC) with NH Amendments
- 2021 International Swimming Pool & Spa Code (ISPSC) with NH Amendments
- 2017 ICCA117.1 and FHA/UFAS as applicable

NOTE: This is a partial list of the adopted codes. The list is provided as a resource for some of the most frequently used codes. Refer to Chapter 2 of NFPA 1 for complete list.

Effective date: August 13, 2024