



TOWN OF BOW

Fire Department

7 Knox Road, Bow NH 03304

Office (603) 223-3960 | Fax (603) 223-3961 | Website www.bownh.gov

Memo

To: Town Manager Stack
From: Chief Harrington *(MHS)*
Date: 1/9/18
Re: Community Building /Cummings Estimate

I have compared the Bob Cummings *Construction Budget Estimate for Fire and Life Safety Upgrades Only* dated 11/22/17 with the *Bow Community Center-Health and Safety Synopsis* dated 11/14/17.

The Cummings Budget Estimate does not address the following:

RPF Associates, Inc.-Mercier 6/26/2009

Line 4 and 5-asbestos abatement

NH Fire Marshals Office-Torri 5/16/2013

Line 3 and 4-electrical deficiencies

NH Fire Marshals Office-Clark 7/24/2013

Line 2-asbestos abatement

Line 3-kitchen hood and clearances

Line 9-electrical deficiencies

Line 12-achieve total compliance by 9/15/16

Yeaton Associates 10/7/2013

Line 3-electrical service grounding and bonding

Line 4-panel clearance from structure components

Line 5-use of tandem electrical breakers

NH Fire Marshals Office-Ansty 11/19/14

Line 2-generator clearances from combustibles and exhaust

Line 10-exposed wood/interior finish

Line 11-exit door threshold

Line 14-generator fuel tank protection

Line 17-mechanical venting

Community Building is being occupied under temporary/waiver status through the NH Fire Marshal's Office; any proposals are subject to their review and approval.